


1. The BOQ schedule A3 Item 3602 states construction of Entrances to Private Property as per design but the Tollemaches Drawings do not indicate any private property entrances. Could you please advise which property entrance is it referring to or if any drawing is missing from the Tender Documents. **Per the snip below, there is a property access in the northern extents of the work site. The driveway is to be reinstated on completion of works in accordance with the attached CMDG Standard Drawing CMDG-R-40.**



2. The typical section (Ch.5680 to 5740) for Tollemaches Road in Drawing number RD-1600-02 indicates the CBR 40 council mix to be placed up to the traffic lane boundary. Could you please confirm the shoulder does not require any top/base course. (Refer to attached snippet) **Yes the gravel is to extend along the shoulders, this increases the quantity of gravel required from 110m3 to 126.5m3 (has been updated on the new Pricing Schedule on the website).**
3. Further to point number 2, it also states Min CBR 7 select fill under the pavement. Could you please confirm it Item No. 3301 of Schedule A3 includes this select fill assuming the site won material will comply with the requirements. There is no other item on the BOQ referring to this select-fill. (Refer to attached snippet) – **Yes item 3301 is the select fill and site won material can be used**
4. Could you please advise if any Geotech report is available for the proposed works (Both Harsants & Tollemaches Rd). If yes, could Council make it available to the tenderers. **Please find attached the factual report for Harsants Road. A report was not undertaken for Tollemaches Road.**

5. Could you please advise if the council has any drawing plans or typical sections for gravel re-sheeting of Harsants Road (CH.2355 to 7100 & CH.0 to CH.2035)? – Please see the section below.



6. Could you please confirm all disposal of spoils & excess materials (including unsuitable) are to be stockpiled at the Council designated stockpile location within 1 km of Tollemaches & Burnett Highway intersection. – Spoil can be temporarily stockpiled on the pad at the Tollemaches intersection but permanent disposal of the spoil at the Trap Gully waste facility (located east of Biloela) or another approved location (can be suggested by the contractor) must be factored into your rates.