

`, \sim β kWh MFM TS · ____ · × ATS × _____ MSAF N-O X.YYY.Z

 \square

Ν

Р1 🔀

o∕×

	GENERAL NOTES: (©) Copyright, Anderson Consulting Engineers Pty. Ltd. Do not scale from this drawing. Take measurements on site prior to commencing work. NOTES (N-) 1. CONDUITS TO HAVE A MINIMUM SPACING OF 300mm TO MEET AS3008 DERATING REQUIREMENTS. 2. REMOVE EXISTING PROPERTY POLE AND CABLING. 3. MEASURE FENCE PRIOR TO ORDERING. ENSURE THAT FENCING DOES NOT OBSTRUCT EMERGENCY EXIT. 4. DISCONNECT EXISTING POINT OF SUPPLY FROM PROPERTY POLE. 5. PROVIDE HAT SECTION OF RISER. COLOUR TO MATCH EXISTING BUILDING.
EXISTING MAIN SWITCHBOARD RISER MAIN SWITCHBOARD ELECTRICAL PIT UNDERGROUND ELECTRICAL ROUTE CIRCUIT BREAKER	
CIRCUIT REPEATED AS NOTED	
SURGE PROTECTION EQUIPMENT	
SUPPLY AUTHORITY METER	
MULTI FUNCTION METER	
TIME SWITCH	16/08/24 B RESOURCE CENTRE CONDUIT ADDED G.A. Date Rev Details App
AUTOMATIC TRANSFER SWITCH	Client: Banana SHIRE SHIRE OF OPPORTUNITY
DENOTES SINGLE PHASE	
DENOTES THREE PHASE	
BUSBAR	ANDERSON
SWITCHBOARD ENCLOSURE	CONSULTING ENGINEERS
MULTI SWITCH AF RECEIVER FOR HOT WATER TARIFF NEW EARTH STAKE IN DEDICATED EARTH	43 Denison Street, Rockhampton, Q. 4700 P.O. Box 27, Rockhampton, Q. 4700 Phone: (07) 4927 2077 Email: admin@andersonce.com.au ACN: 112 066 529 ABN: 98 112 066 529
PIT AT SWITCHBOARD. ALLOW TO REMOVE A SECTION OF CONCRETE.	
REFER NOTES ON DRAWING	BILOELA CIVIC CENTRE CNR RAINBOW AND PRAIRIE
X - DENOTES NUMBER OF CONDUITS YYY - DENOTES CONDUIT DIAMETER IN mm ²	STREETS, BILOELA
 Z - DENOTES CONDUIT TYPE AS FOLLOWS: E - DENOTES HD PVC UNDERGROUND ELECTRICAL 	MAIN SWITCHBOARD
 CONDUIT FOR LOW VOLTAGE CABLING C - DENOTES ACA APPROVED UNDERGROUND COMMUNICATIONS CONDUIT 	REPLACEMENT.
 COMMUNICATIONS CONDUIT M - DENOTES MISCELLANEOUS CONDUIT HV - DENOTES HD PVC UNDERGROUND ELECTRICAL CONDUIT FOR HIGH VOLTAGE CABLING 	
	SITE PLAN.
LEGEND NOT TO SCALE	
	Drawing No: Rev:
	23165C-E002 B
	Drawn: Designed: B.M.
	Scale @ A1: APPROX 1:400 G.A.

Date:

APRIL 24

No: Of: 2